

## Short Form Classification Report No. 16336G

- 1 - Classification report reference and date  
16336E written in English : 19-02-2014
- 2 - Sponsor of the report : **Solicom sa**
- 3 - Testing lab: Warringtonfiregent (WFRGENT nv)
- 4 - Standard:  
For testing: EN ISO 11925-2 (2010/AC:2011) and EN 13823 (2010)  
For classification: EN 13501-1:2007+A1:2009
- 5 - Tested product: **Verisafe® FR**
- 6 - Classification: **B-s1, d0**
- 7 – Field of application:
  - Freestanding
  - Without joints

This classification is valid for the following product parameters:

- The product Verisafe® FR is a polyethylene (PE) foil
- Nominal thickness: All thicknesses between or equal to 180 µm and 320 µm
- Nominal density: 1000 kg/m<sup>3</sup>
- Use of fire retardant: Yes
- Amount of fire retardant: 10 %
- Colour: White

SIGNED

APPROVED

*This short form classification report has been drafted according to EGOLF regulation R4 "Application note: clause 5.10 [5.10/1] – Issue 01- 2002-06-21 – Types of test reports used in fire testing". Whilst the test data and classification provided within this short report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2 (2010/AC:2011), EN 13823 (2010) and EN 13501-1:2007+A1:2009, the presentation of the results in this short form may not satisfy the requirements of that standard and EN ISO/IEC 17025: 2005/AC: 2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted. The full classification report No. 16336E is available at **Solicom sa**.*

This document is the original version of this document and is written in English. This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.